

कार्यालय— नगर स्वास्थ्य अधिकारी, नगर निगम वाराणसी

अनापत्ति प्रमाण पत्र

सेवा में,

Sunbeam English School Bhagwanpur,
206 Lanka, Bhagwanpur, Varanasi.
Uttar Pradesh 221005.

पत्रांक— 281/SBm/vns/23-24

दिनांक— 19.02.24

विषय: स्वच्छता प्रमाण पत्र दिये जाने के सम्बन्ध में ।

महोदय,


उपरोक्त विषयक आपके संस्थान (Sunbeam English School Bhagwanpur, Lanka Bhagwanpur Varanasi) द्वारा प्रेषित पत्र दिनांक 29.01.2024 का संदर्भ ग्रहण करने का कष्ट करें जो स्वच्छता के सम्बन्धित अनापत्ति प्रमाण-पत्र की मांग किये जाने के सम्बन्ध में है।

उक्त के सम्बन्ध में विद्यालय परिसर की दिनांक 07.02.2024 को जांच की गयी। जांचोंपरान्त स्वच्छता संतोषजनक पायी गयी है।

अनापत्ति प्रमाण-पत्र निम्न शर्तों के साथ जारी किया जाता है—

1. परिसर के अन्दर एवं बाहर पूरे वर्ष भर साफ-सफाई रखा जाय।
2. परिसर के अन्दर का शौचालय एवं मूत्रालय पूरे वर्ष भर साफ एवं स्वच्छ रखा जाय।
3. परिसर से उत्सर्जित गीले एवं सूखे कूड़े का सम्यक निस्तारण नियमानुसार करें।
4. शासन द्वारा प्रतिबन्धित प्लास्टिक कैंरिबैग एवं प्लास्टिक या थर्मोकोल इत्यादि का प्रयोग आपके प्रतिष्ठान द्वारा नहीं किया जायेगा।
5. स्वच्छ भारत मिशन के गाइडलाइन का पालन किया जायेगा।
6. ऐसा कोई भी कार्य नहीं किया जायेगा विद्यार्थियों के स्वास्थ्य के विपरीत हो।
7. आकस्मिक निरीक्षण के दौरान उपरोक्त बिन्दुओं से सम्बन्धित किसी प्रकार की कमी पाये जाने पर यह अनापत्ति प्रमाण-पत्र स्वतः निरस्त माना जायेगा।

नोट:— उक्त अनापत्ति प्रमाण-पत्र जारी होने के दिनांक से एक वर्ष के लिए वैध होगा।


19.02.2024
नगर स्वास्थ्य अधिकारी
नगर निगम वाराणसी



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)

(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)

Website: www.itslab.in, Email: itrlclab@gmail.com, info@itslab.in, contact@itslab.in

+91 9911659800, 9305780312, 09958849764



TEST REPORT

Water Sample Analysis

Report Code: W-290324-12

Issue Date: 03/04/2024

ISSUED TO: M/S. SUNBEAM ENGLISH SCHOOL

206, Bhagwanpur (Near Trauma Centre), Varanasi, Uttar Pradesh

SAMPLING & ANALYSIS DATA

Sample Description	: Drinking Water (RO Water)
Sample Drawn On	: 28/03/2024
Sample Drawn By	: Mr. Manpal Yadav (ITS Representative)
Sampling Plan & Procedure	: IS:17614 (Part):2021
Sample Quantity	: 2.0 Liter in Pet Bottle
Sample Received On	: 29/03/2024
Analysis Duration	: 29/03/2024 To 03/04/2024
ULR No.	: TC1118124000000303

TEST RESULTS

Chemical Analysis						
S. No.	Parameter	Test Method	Results	Units	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH	IS:3025(Part-11)	6.87	-	6.5 - 8.5	-
2.	Colour	IS:3025(Part-4)	<5.0	Hazen	5	15
3.	Turbidity	IS:3025(Part-10)	<1.0	NTU	1	5
4.	Total Hardness (as CaCO ₃)	IS:3025(Part-21)	32.0	mg/l	200	600
5.	Chloride(as Cl)	IS:3025(Part-32)	18.0	mg/l	250	1000
6.	Calcium (as Ca)	IS: 3025 (P- 40)	6.0	mg/l	75	200
7.	Iron (as Fe)	IS:3025(Part-53)	<0.05	mg/l	1.0	-
8.	Nitrate (as NO ₃)	IS: 3025 (P- 34)	<1.0	mg/l	45	No Relaxation
9.	Total Dissolved Solid	IS:3025(Part-16)	64	mg/l	500	2000
10.	Alkalinity (as CaCO ₃)	IS: 3025 (P- 23)	16.0	mg/l	200	600
11.	Fluoride (as F)	IS: 3025 (P- 60)	<0.1	mg/l	1.0	1.5
12.	Sulphate (as SO ₄)	IS:3025 (P-24)	<1.0	mg/l	200	400
13.	Magnesium (as Mg)	IS:3025 (P-46)	3.66	mg/l	30	100


Microbiological Analysis

RESULTS				
S.No.	Parameter	Test Method	Results	Required as per IS-10500:2018
1.	<i>Escherichia coli</i>	IS-15185:2016	Absent	Absent/100ml
2.	<i>Coliform Bacteria</i>	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter. Water sample meets as per IS-10500:2018 specification. Hence water is fit for Drinking purpose.

Authorized Signatory

(Microbiologist)



Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrlab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764




Report Code: W-290324-12 , Page- 2 of 2

MICROBIOLOGICAL REQUIREMENT

		RESULTS		
S.No.	Parameter	Test Method	Results	Required as per IS-10500:2018
1.	<i>Escherichia coli</i>	IS-15185:2016	Absent	Absent/100ml
2.	<i>Coliform Bacteria</i>	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter. Water sample meets as per IS-10500:2018 specification.
Hence water is fit for Drinking purpose.


CHECKED BY


Babita Dharwal
AUTHORIZED SIGNATORY

Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.